



GENERAL NOTES:

- 1. COORDINATE INSTALLATION OF DEVICES WITH STERIS EQUIPMENT PROVIDER/INSTALLER, CASEWORK PROVIDER, AND ELEVATIONS
- 2. TELECOM OUTLETS: THE NUMBER ADJACENT TO THE DEVICE
- 3. EXISTING FIRE ALARM DEVICES REMOVED DURING DEMOLITION MAY
- 4. EXPAND EXISTING HOSPITAL PUBLIC ADDRESS SYSTEM. EQUIPMENT IS LOCATED IN ROOM 105. PROVIDE ALL LABOR AND MATERIAL REQUIRED FOR A COMPLETE TURN KEY SYSTEM. REFER TO PLAN FOR SPEAKER LOCATIONS. SPEAKERS SHALL BE 8" FLUSH AND/OR A SURFACE MOUNTED, MULTIPLE TAPS, DUAL CORE LOUDSPEAKER ASSEMBLIES FOR VOICE OR MUSIC REPRODUCTION,
- 5. EXISTING SIMPLEX 4100 FIRE ALARM CONTROL PANEL IN ROOM 105.
- 1 PROVIDE ROUGH-IN FOR CARD ACCESS SYSTEM READER.
- 2 PROVIDE AND INSTALL 12" WIDE X 4" DEEP CABLE TRAY SYSTEM. 3" NEMA LOADING DEPTH, ALUMINUM, 9" RUNG
- 3 PROVIDE AND INSTALL FOUR (4) 4" EMT CONDUITS FOR
- 5 PROVIDE ROUGH-IN FOR CCTV CAMERA. INSTALL SINGLE
- 6 PROVIDE ONE ETHERNET CONNECTION FOR STERILIZER

- 9 PROVIDE ETHERNET CONNECTION FOR CART WASH
- 12 PROVIDE (3) 4" CONDUIT SLEEVES THROUGH WALL.
- 13 DUAL CHANNEL POWER POLE. REFER TO POWER PLAN.
- 14 REINSTALL EXISTING FIRE ALARM DEVICES REMOVED DURING
- 15 INSTALL RELOCATED LOGISTICS INTRUSION DETECTION SYSTEM PANEL DEVICES. COORDINATE LOCATION OF PANEL
- 16 INSTALL RELOCATED PHARMACY STORAGE INTRUSION
- INTRUSION DETECTION SYSTEM. PROVIDE ONE KEYPAD ARMING STATION, ONE MOTION SENSOR AND CONNECT TO EXISTING FIRST FLOOR SECURITY OFFICE. COORDINATE LAYOUT WITH TELECOM EQUIPMENT. SYSTEM SHALL MATCH
- DEMOLITION. ROUTE CONDUIT AND CONDUCTORS CONCEALED TO EXISTING HEADEND EQUIPMENT.
- 20 PROVIDE NEW CARD READER WITH KEYPAD AND CONNECT TO
- FIRE PROTECTION SYSTEM. COORDINATE QUANTITY AND LOCATION WITH FIRE PROTECTION CONTRACTOR.
- 22 PROVIDE DUCT DETECTOR IN AHU SUPPLY DUCT.
- 23 PROVIDE NEW SECURITY CAMERA. PROVIDE ALL LABOR AND MATERIALS NECASSARY TO ACTIVATE AT EXISTING HEAD END EQUIPMENT. DEVICE SHALL MATCH AND BE COMPATIBLE WITH
- TO RTLS RACK. PROVIDE 20' COIL AND TAG CABLE. RACK AND TERMINATION BY SONITOR RTLS SUPPLIER. COORDINATE
- (TYPICAL). PROVIDE (1) CAT 6 CABLE AND ONE OR TWO PORT BISCUIT BLOCK. PROVIDE 10' COIL. PATCH CABLE, RTLS DEVICES AND TERMINATION BY RTLS SUPPLIER. COORDINATE

100% CONSTRUCTION DOCUMENTS **FULLY SPRINKLERED**

Date: June 10, 2015

Revisions: Amendment 04

2121 Lake Ave. Fort Wayne, IN 46805

7260 SHADELAND STATION INDIANAPOLIS, IN 46256-3957 TEL 317.547.5580 FAX 317.543.0270 www.structurepoint.com

8250 Haverstick Road Suite 285 Indianapolis, IN 46240 317.638.8383

Checked Drawn

Checker

Author

08/15/2014

Office of Construction and Facilities Management

VA Department of Veterans Affairs

LUMINAIRE SCHEDULE MANUFACTURER **BALLAST** /CATALOG # REMARKS LAMPS LAMP TYPE TYPE VOLTAGE **MARK** DESCRIPTION NOMINAL 2' X 4' X 6" HIGH RECESSED LED TROFFER, WHITE 20 GA COLD STEEL KENALL ME SERIES, NOTE 1, 4, 5, 9, 120 V 50W INTEGRAL HOUSING, FULLY GASKETED, SEALED LUMINOUS IMPACT RESISTANT DR ACRYLIC FAILSAFE; KURTZON, 72, 13, 14 LENS, TOOL-LESS ACCESS, HINGED DOOR FRAME NEW STAR STARCLEAN CREE AR22; FINELITE NOTE 1, 3, 4, 6, NOMINAL 2' X 2' X 4" HIGH RECESSED LED TROFFER, WHITE 20 GA COLD STEEL 32W INTEGRAL 120 V HOUSING, SINGLE SATINE EXTRUDED ACRYLIC LENS WITH UV INHIBITORS, CENTER HPR; PINNACLE SPINE, HINGED DOOR FRAME, WHITE TRIM LUCEN; CORELITE 40W INTEGRAL NOMINAL 2' X 4' X 4" HIGH RECESSED LED TROFFER, WHITE 20 GA COLD STEEL 120 V CREE AR24; FINELITE NOTE 1, 2, 3, 4, HOUSING, SINGLE SATINE EXTRUDED ACRYLIC LENS WITH UV INHIBITORS, CENTER HPR; PINNACLE SPINE, HINGED DOOR FRAME, WHITE TRIM LUCEN; CORELITE NOMINAL 6" DIA X 7" HIGH DEEP RECESSED LED DOWNLIGHT MODULE WITH CLEAR | CREPTISHTING KR6 | NOTE 2, 3, 4, 5, 12W INTEGRAL 120 V DIFFUSED REFLECTOR, WHITE FLANGE SERIES, GOTHAM, PORTFOLIO, PRESCOLITE PINNACLE LUCEN; NOTE 1, 3, 4, 6, NOMINAL 1' X 4' X 4" HIGH RECESSED LED TROFFER, WHITE 20 GA COLD STEEL 40W INTEGRAL 120 V HOUSING, SINGLE SATINE EXTRUDED ACRYLIC LENS WITH UV INHIBITORS, CENTER | FINELITE HPR; SPINE, HINGED DOOR FRAME, WHITE TRIM 120 V NOMINAL 1' X 4' X 4" HIGH RECESSED LED TROFFER, WHITE 20 GA COLD STEEL SAME AS TYPE 'E' WITH NOTE 1, 3, 4, 6, 40W INTEGRAL HOUSING, SINGLE SATINE EXTRUDED ACRYLIC LENS WITH UV INHIBITORS, CENTER EMERGENCY BALLAST 12, 13, 14 SPINE, HINGED DOOR FRAME, WHITE TRIM NOMINAL 2' X 4' X 4" HIGH RECESSED LED TROFFER, WHITE 20 GA COLD STEEL CREE AR24; FINELITE | NDTE 1, 2, 3, 4, 40W INTEGRAL 120 V HOUSING, SINGLE SATINE EXTRUDED ACRYLIC LENS WITH UV INHIBITORS, CENTER HPR; PINNACLE SPINE, HINGED DOOR FRAME, WHITE TRIM RAILS, 50% STEP DIMMING LUCEN; CORELITE 2' X 4' LENSED TROFFER, RECESSED, DIE-FORMED COLD-ROLLED STEEL HOUSING SAME AS TYPE 'F' WITH NOTE 1, 3, 4, 6, 120 V 40W INTEGRAL POSITIVE CAM ACTION STEEL LATCHES, INTEGRAL SAFETY HINGES, ACRYLIC LENS, EMERG BATTERY 12, 13, 14 PREMIUM REFLECTANCE BAKED WHITE ENAMEL FINISH, UL LISTED FOR DAMP NOMINAL 1' X 4' X 5" HIGH SURFACE MOUNTED LENSED LED VAPORTITE LUMINAIRE, LITHONIA FEM SERIES, NOTE 1, 3, 4, 5, 120 V LED FURNISHED WHITE 20 GA COLD STEEL HOUSING METALUX, COLUMBIA, 13, 14 WITH LUMINAIRE NOMINAL 3" W X 4' X 4" HIGH CHAIN HUNG LENSED LED INDUSTRIAL LUMINAIRE, METALUX SNLED NOTE 1, 3, 9, 50W INTEGRAL 120 V WHITE 20 GA COLD STEEL HOUSING, CHAIN MTD SERIES, LITHONIA. COLUMBIA, CREE 50W INTEGRAL 120 V NOMINAL 3" W X 4' X 4" HIGH CHAIN HUNG LENSED LED INDUSTRIAL LUMINAIRE, METALUX SNLED NOTE 1, 3, 9, WHITE 20 GA COLD STEEL HOUSING, CHAIN MTD SERIES, LITHONIA, 12, 13, 14 COLUMBIA, CREE NOMINAL 6" X 48" L X 3.75" HIGH WALL MOUNTED LED OVERMIRROR LUMINAIRE, 120 V KENALL MLHA5 50W INTEGRAL SERIES, FAILSAFE, NOTE 1, 3, 4, 6, EXTRUDED ALUM HOUSING, FULLY GASKETED, SEALED LUMINOUS IMPACT RESISTANT PEARLESCENT LENS, ADA COMPLIANT, STEPPED END CAP, WHITE NEW STAR VN SERIES 9, 12, 14 NOMINAL 6" X 48" L SURFACE MOUNTED LED STAIR LUMINAIRE WITH INTEGRAL 120 V LITHONIA WL SERIES; WALL MOUNT. LED FURNISHED OCCUPANCY SENSOR, WHITE FINISH COLUMBIA; LUMINAIRE | NOTE 3, 4, 6, 9, WITH LUMINAIRE NOMINAL 15" W X 9" H X 12" D WALL MOUNTED EXTERIOR LED LUMINAIRE WITH DIE KENALL FN15L, CREE NOTE 3, 4, 5, 9, 26 W INTEGRAL CAST ALUMINUM HOUSING, TYPE III DISTRIBUTION, FULL CUTOFF, UV STABILIZED XSPW, LUMARK, 12, 13, 14 LED POLYCARBONATE LENS, DARK BRONZE FINISH DIE CAST ALUMINUM HOUSING, LED DIRECTIONAL ARROWS AS INDICATED, STENCIL LITHONIA LQM, NOTE 3, 13, 15 120 V LED FURNISHED

DUAL-LITE, SURE LITES

WITH LUMINAIRE

LUMINAIRE SCHEDULE GENERAL NOTES:

ALL LUMINAIRES SHOWN ON THIS SCHEDULE MAY NOT BE USED ON THE VARIOUS PLANS. ALSO, THE USE OF ONLY CERTAIN NUMERICAL SUBSCRIPTS FOR LUMINAIRE TYPES (e.g. H2, H3, A2, A3, etc.) ON THIS PROJECT DOES NOT NECESSARILY MEAN THAT ON H1 OR A1 IS USED OR MISSING.

CONTRACTOR IS RESPONSIBLE FOR ALL MISCELLANEOUS HARDWARE, CLIPS, ANGLES, FRAMES, ETC. AS REQUIRED TO MOUNT THE LUMINAIRES IN OR ON THE SURFACES THEY ARE TO BE INSTALLED.

3. REFER TO ARCHITECTURAL DOCUMENTS FOR EXACT MOUNTING LOCATIONS OF LUMINAIRES.

WHEN INSTALLING LUMINARIES, THE CONTRACTOR SHALL USE THE LUMINAIRE MANUFACTURER'S MOUNTING HARDWARE AND FOLLOW ALL MANUFACTURER'S INSTALLATION DIRECTIONS.

5. ALL RECESSED DOWNLIGHTS MUST BE INSTALLED SO THAT THE BOTTOM OF THE THROAT IS EVEN WITH THE FINISHED CEILING PLANE. THE OVERLAPPING FLANGE MUST THEN FIT FLUSH TO THE CEILING PLANE/THROAT. NO LIGHT LEAK MUST BE VISIBLE. ALL MISCELLANEOUS HARDWARE ABOVE THE CEILING PLANE TO ACCOMPLISH THE ABOVE SHALL BE INCLUDED IN THE BASE BID.

ALL RECESSED DOWNLIGHTS SHALL HAVE SELF-FLANGED REFLECTORS UNLESS OTHERWISE NOTED.

7. ALL LUMINAIRES SHALL HAVE A U.L. LABEL.

8. WHEN INSTALLING COMPACT FLUORESCENT LAMP LUMINARIES; CONSISTENT LAMP ORIENTATION SHALL BE MAINTAINED IN A GIVEN AREA.

IN ALL MECHANICAL ELECTRICAL EQUIPMENT AREAS, CONTRACTOR TO COORDINATE LUMINAIRE LOCATIONS SUCH THAT LUMINAIRES RUN PARALLEL TO THE FACE OF THE EQUIPMENT AND OVER AISLES BETWEEN EQUIPMENT. INSTALL AT EXACT LOCATIONS AND AT EXACT HEIGHT TO ILLUMINATE ALL GAGES, PANELS, CONTROLS, VALVES, ETC. CHAIN HANGING, STEM HANGING, UNISTRUT HANGING, ETC. ARE ACCEPTABLE METHODS.

10. ALL LUMINAIRES SHALL OPERATE AT 120 OR 277 VOLTS OR OTHER VOLTAGE AS REQUIRED BY THE CIRCUITS AND/OR PANELS TO WHICH THEY ARE

11. WHEN LUMINAIRES ARE INSTALLED IN CONTINUOUS ROWS 2 OR MORE, LUMINAIRES SHALL BE APPROVED FOR USE AS WIREWAY.

12. <u>REFER TO SPECIFICATION SECTIONS 265100 AND 265600 FOR ADDITIONAL INFORMATION CONCERNING LUMINAIRES, FINISHES, DRIVERS, LAMPS, ETC.</u>

LUMINAIRE SCHEDULE REMARKS:

LUMINAIRE TO BE SWITCHED.

2. LUMINAIRE TO BE DIMMED VIA SELECTED DIMMING CONTROLS. COORDINATE DIMMING REQUIREMENTS WITH LUMINAIRE MANUFACTURER.

LUMINAIRE SHALL HAVE A MINIMUM FULL 5-YEAR WARRANTY.

CONTRACTOR TO VERIFY AND COORDINATE LUMINAIRE INSTALLATION AND MOUNTING WITH ARCHITECTURAL DETAILS, HOUSING TYPE, FIELD CONDITIONS, AND CEILING SYSTEM DETAILS, INCLUDING FLANGE REQUIREMENTS.

LUMINAIRE TO BE U.L. LISTED AND LABELED "SUITABLE FOR WET LOCATIONS".

LUMINAIRE TO BE U.L. LISTED AND LABELED "SUITABLE FOR DAMP LOCATIONS."

PROVIDE WIRE GUARD FOR LUMINAIRE.

LUMINAIRE SHALL BE MOUNTED AGAINST CABINET FASCIA WITH LENS

FACING TOWARD WALL. UTILIZE MULTI-VOLT (120/277V) BALLAST.

PROVIDE TWO BALLASTS PER LUMINAIRE.

PROVIDE CORD & PLUG OPTION.

LUMEN MAINTENANCE (L70) RATED 50,000 HOURS MINIMUM.

PROVIDE INTEGRAL EMERGENCY BATTERY. PROVIDE 4000 KELVIN TEMPERATURE.

UNIVERSAL MOUNT.

													EQUIPMENT DA	TA SCHEDU	JLE													
				MOTOR OR E					MOTOR OR	EQUIPMENT	i																	
PLAN MAR	K	LOCATION			DATA				DA	ΔTA			DISCONNECT SWITCH AT EQUIPMENT							STARTER					(
			ROOM	FURNISHED						INSTALLED	CONNECTED	FFN	FEEDER OR BRANCH CIRCUIT		NEMA ENCLOS.	SWITCH/ FUSE	FURNISH		CONN.	NEMA	NEMA ENCLOS.		BREAKER	ACCES.	FURNISH.	CONN.	CONTRO	
	EQUIPMENT	ROOM NAME	NUMBER	BY (1)	НР	KW	AMPS	VOLTS	PHASE		BY	FROM	(2)	TYPE (3)	TYPE	SIZE	BY	INST. BY	BY	SIZE	TYPE	TYPE (4)		(5)	BY	RY	BY	$\begin{array}{c c} & \text{KEMARN} \\ \hline & (6) \end{array}$
AHU 1	AIR HANDLING UNIT	ON ROOF	TOWIDER	23	25	0	34	480	3	23	26	BEQH1-3	3#8, 1#8 IN 3/4"C.	NF	NEMA 3R	60A	26	26	26		NEMA 1	VFD	/ / / / / / / / / / / / / / / / / / /		26	26	23	
CGP 1	CHILLED WATER GLYCOL PUMP	WATER TREATMENT	49C	23	0	0	7	120	1	23	26	BEQL2-20	2#12, 1#12 IN 3/4"C.									PWCP					23	2
CH 1	CHILLER	ON ROOF		23	1	80	96	480	3	23	26	BEQH1-1	3#3/0, 1#6 IN 2"C.	F	NEMA 3R	200A	26	26	26		NEMA 3R	PWCP			23	26	23	
CU 1	DUCTLESS SPLIT SYSTEM	O.I.T.	53	23	0	7	15	208	1	23	26	TELE-C-18, 20	2#12, 1#12 IN 3/4"C.	F	NEMA 3R	15A	26	26	26								23	6
CUH 1	CCABINET UNIT HEATERR	STAIR 1	B-C-ST1	:23	0	0	1	120	1	23	26	BNL2-1-31	2#12, 1#12 IN 3/4"C.														23	2,4
CUH 2	CABINET UNIT HEATER	STORAGE (FUTURE STAIRS)	B-C-ST2	23	0	0	1	120	1	23	26	BNL2-2-33	2#12, 1#12 IN 3/4"C.														23	2,4
CWP 1	CHILLED WATER PUMP		49C	23	8	0	11	480	3	23	26	BEQH1-7	3#12, 1#12 IN 3/4"C.								NEMA 1	VFD			26	26	23	5
CWP 2	CHILLED WATER PUMP		49C	23	8	0	11	480	3	23	26	BEQH1-8	3#12, 1#12 IN 3/4"C								NEMA 1	VFD			26	26	23	5
EF 1	EXHAUST FAN	ON ROOF		23	10	0	14	480	3	23	26	BEQH1-4	3#10, 1#10 IN 3/4"C	F	NEMA 3R	30A	26	26	26									
EF 2	EXHAUST FAN	ON ROOF		23	1/3	0	7	120	1	23	26	BCRL2-8	3#12, 1#12 IN 3/4"C	TOG	NEMA 3R	20A	26	26	26									
EF 3	EXHAUST FAN	ON ROOF		23	3/4	0	14	480	3	23	26	BEQH1-2	3#12, 1#12 IN 3/4"C	F	NEMA 3R	30A	26	26	26									
HGP 1	HEAT RECOVERY GLYCOL PUMP	WATER TREATMENT	49C	23	0	0	7	120	1	23	26	BEQL2-20	2#12, 1#12 IN 3/4"C.									PWCP					23	2
HRP 1	HEAT RECOVERY PUMP	WATER TREATMENT	49C	23	1.5	0	5	480	3	23	26	BEQH1-9	3#12, 1#12 IN 3/4"C								NEMA 1	VFD			26	26	23	5
HRP 2	HEAT RECOVERY PUMP		49C	23	1.5	0	5	480	3	23	26	BEQH1-10	3#12, 1#12 IN 3/4"C								NEMA 1	VFD			26	26	23	5
HWP 1		WATER TREATMENT	49C	23	2	0	3	480	3	23	26	BEQH1-5	3#12, 1#12 IN 3/4"C								NEMA 1	VFD			26	26	23	5
HWP 2		WATER TREATMENT	49C	23	2	0	3	480	3	23	26	BEQH1-6	3#12, 1#12 IN 3/4"C								NEMA 1	VFD			26	26	23	5
HWRP 1	HOT WATER RECIRCULAING PUMP			22	0	0	0	120	1	22	26		2#12, 1#12 IN 3/4"C.	TOG	NEMA 1	20A	26	26	26								23	
SP 1	SUMP PUMP	CHILLER ROOM	B-C-120	22	1	0	0	120	1	22	26		2#12, 1#12 IN 3/4"C.	TOG	NEMA 1	20A	22	22	26								23	
UH 1	UNIT HEATER	CHILLER ROOM	B-C-120	23	1	0	1	120	1	23	26	BEQL2-18	2#12, 1#12 IN 3/4"C.	TOG	NEMA 1	20A	26	26	26								23	
DIV DIV	ECIFICATION DIVISION NUMBE /ISION 23 - MECHANICAL /ISION 26 - ELECTRICAL	THIS COLUMN CONTAINS A FEEDER F - FU DESIGNATION INSTEAD OF TOG - TO					- NON FUS - FUSED G - TOGGLE C - DUPLEX	Ξ	COMB1 - COMBINATION FULL VOLTAGE NON-F MAGNETIC STARTER WITH FUSED DIS					ISCONNECT SWITCH REVERSING MAGNETIC REVERSING MAGNE							SORIES: - HOA WITH PII - START/STOP (MOMENTAR)		 (6) KEY TO REMARKS: FIRE ALARM INTERLOCK INTEGRAL DISCONNECT SWITCH BY DIVISION 23 MOUNT DISCONNECT SWITCH ON EQUIPMENT HOUSING LESS THAN 1/8 HP, BRANCH CIRCUIT BREAKER MEANS OF DISCONNECT. INTEGRAL DISCONNECT IN VFD BY DIVISION 23. 					

100% CONSTRUCTION DOCUMENTS **FULLY SPRINKLERED**

Date: June 10, 2015

Revisions: Amendment 04

VA FORM 08-6231

VA NORTHERN INDIANA HEALTH CARE SYSTEM, FORT WAYNE 2121 Lake Ave. Fort Wayne, IN 46805

3

ARCHITECT/ENGINEERS: STRUCTUREPOINT 7260 SHADELAND STATION INDIANAPOLIS, IN 46256-3957 TEL 317.547.5580 FAX 317.543.0270 www.structurepoint.com

Ross Baruzzini 8250 Haverstick Road Suite 285 Indianapolis, IN 46240

317.638.8383

CONSULTANTS:

5 6

Project Title Drawing Title Project Number SPS BASEMENT ADDITION ELECTRICAL SCHEDULES 2010.00629.0005 VA PROJECT # 610A4-12-400 **Building Number** 01 Approved: Project Director Drawing Number 2121 Lake Ave. Fort Wayne, IN 46805 E600 Drawn Checked 08/15/2014 Checker Author

Office of Construction and Facilities Management VA Department of Veterans Affairs